

## **October 2012 FISHWAY INSPECTION SUMMARY**

Fishway Inspections were conducted at most Columbia and Snake River Dams fitted with adult fish passage structures over October of 2012.

Several issues were encountered over October 2012, issues encountered are listed below.

Bonneville Dam (October 24, 2012): Bonneville B-Branch out of service for FV 4-4 repair.

Lower Granite Dam (October 26, 2012): Fishway exit not clean.

Little Goose Dam (October 23, 2012): Fish Pump #3 out of service, NPE2 closed.