

**Table 7. Pertinent Data for Fish Facility Inspections in 2014 at LITTLE GOOSE DAM.**

<u>CRITERIA ITEMS</u>	<u>DATE OF INSPECTION</u>							
		<u>30-Apr</u>	<u>28-May</u>	<u>26-Jun</u>	<u>30-Jul</u>	<u>28-Aug</u>	<u>22-Sep</u>	<u>22-Oct</u>
<b>SOUTH SHORE FISHWAY</b>								
<b><i>South Shore Entrance:</i></b>								
<u>Depth over entrance weir</u>								
SSE-1 (Criteria = 8 ft or >)	ft	8.6	8.3	8.3	8.3	8.2	8.2	8.3
SSE-2 (Criteria = 8 ft or >)	ft	8.7	8.2	8.3	8.1	8.1	8.1	8.2
Head at SSE-1 & 2 (Criteria = 1-2 ft)	ft	1.2	1.5	1.4	1.4	1.4	1.4	1.3
Dep. over ladr. weir (Crit. = 1-1.3 ft)	ft	1.2	1.2	1.2	1.2	1.2	1.2	1.2
Channel velocity (Criteria = 1.5-4 fps)	fps	2.6	2.6	1.6	2.1	1.7	1.7	2.3
Channel velocity (North Shore)	fps	2.9	2.4	2.2	2.0	2.2	2.1	2.4
Ladder exit clean (yes or no)		yes	yes	yes	yes	yes	yes	yes
Staff gages clean (yes or no)		yes	yes	yes	yes	yes	yes	yes
Picket leads clean (Criteria = 0.3' max)		yes	yes	yes	yes	yes	yes	yes
<b><i>North Powerhouse Entrance:</i></b>								
<u>Depth over entrance weir</u>								
NPE-1 (Criteria = 7 ft or >)	ft	5.6	7.2	5.3	5.2	5.6	6.6	7.1
NPE-2 (Criteria = 7 ft or >)	ft	5.6	7.2	5.5	5.4	5.8	6.6	7.1
Head at NPE-1 & 2 (Criteria = 1-2 ft)	ft	1.6	1.5	1.9	1.8	1.9	1.6	1.6
Gate on Sill (Yes or No)		yes	yes	yes	yes	yes	yes	yes
Staff gages clean		yes	yes	yes	yes	yes	yes	yes
Pump speed	rpm	69-71	71	69-71	70-73	71-73	69-71	67-69
Pumps Operating (3 available)		3	3	3	3	3	3	3
<b><i>North Shore Entrance:</i></b>								
<u>Depth over entrance weir</u>								
NSE-1 (Criteria = 6 ft or >)	ft	6.2	7.2	5.6	5.4	4.7	5.9	7.0
NSE-2 (Criteria = 6 ft or >)	ft	6.2	7.2	5.6	5.4	4.7	7.0	7.0
Head at NSE-1 & 2 (Criteria = 1-2 ft)	ft	0.7	1.1	1.2	1.3	2.1	1.0	0.8
Staff gages clean		yes	yes	yes	yes	yes	yes	yes
Comment number (if applicable)		1	2				3	4
<b>Comments:</b>								
1. Most transducers not communicating with FSC board, electronic data from FSC board will not be available this year.								
2. Most transducers not communicating with FSC board. NSE weirs manually positioned at 532.0 ft this year.								
3. Viewing windows dirty, Electronic readings at NSE questionable compared to physical readings.								
4. Head differential at NSE below criteria per staff gauges, within criteria electronic reading.								

